

***Annual Drinking Water Quality Report for 2022***  
**Village of Fort Edward & Town of Fort Edward WD #2**  
118 Broadway, Fort Edward, NY 12828  
Public Water Supply Identification Number NY5700119 & NY5730110

**INTRODUCTION**

To comply with State regulations, the Village of Fort Edward will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your drinking water met all State drinking water health standards. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to New York State standards. Our constant goal is and always has been, to provide to you a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and to protect our water resources. If you have any questions concerning this report or concerning your drinking water please contact: *Mr. Bill Caprood, Water Superintendent, Village of Fort Edward, 99 Reservoir Road, Fort Edward, NY 12828; Telephone (518) 792-0419.* We want our valued customers to be informed about their water service. If you want to learn more, please attend any of our regularly scheduled Village Board meetings. They are held on the 1<sup>st</sup> Monday of each month, 7:00 PM at the *Village Hall, 118 Broadway, Fort Edward, NY 12828; Telephone (518) 747-4023.*

**WHERE DOES OUR WATER COME FROM?**

The source of water for the Village of Fort Edward Water System consists of a watershed of roughly 720 acres. The watershed contains four (4) reservoirs, two (2) wells and three (3) spring collection boxes. Although all components of the water supply system are interconnected, they may be described as forming two distinct systems. The two reservoirs and two wells comprise one water system. The other system consists of two additional reservoirs and three spring collection boxes. The water from this second system is also pumped to the treatment plant. All the reservoirs in the watershed are fed either directly or indirectly by groundwater as well as surface runoff. The primary source used by the Village is Dority Reservoir.

In the early 1980's volatile organic compounds were discovered in one of the streams feeding the New Reservoir. Some of the compounds detected were trichloroethene and cis 1,2-dichloroethene. In order to remediate this problem a forced air stripper was constructed to remove any of the volatiles that may be present. The stripped water is returned to the stream feeding the New Reservoir. The New Reservoir is an emergency supply that has not been used in recent years. Volatile organic chemical samples are collected monthly to verify the air stripper is working properly. There have been no detected concentrations in the finished water for any of the 53 volatiles measured monthly. Copies of these reports may be obtained from the Village of Fort Edward.

The Village operates a state-of-the-art water filtration facility capable of treating more than 1,250,000 gallons of water per day. The new facility is a DualSand™ system by Parkson Corporation. Additionally, a small amount of coagulant (polyaluminum chloride- PCH180) is added to increase the removal of solids. The water is chlorinated to kill bacteria and other microorganisms. We also add sodium hydroxide for pH control of the finished water.

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and EPA prescribe regulations, which limit the amount of certain contaminants in water, provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

**FACTS AND FIGURES**

The Village provides water through approximately 1,300 residential services and approximately 12 industrial and commercial customers to a population of approximately 3,300 people. Fort Edward Water District #2 consists of approximately 34 residential services located on Rt. 4 across the Champlain Canal at the south end of the Village of Fort Edward is also supplied with water from the Fort Edward Water Treatment Plant. Our average daily demand is 326,000 gallons. Our single highest day was 527,000 gallons. The total water withdrawn in 2022 was 128,518,000 gallons. The amount of water treated was 119,339,000. The amount of water delivered to customers was 112,479,000 gallons. Unaccounted for water was 6,860,000 gallons or 5.7%. from filter backwashing (waste to lagoon was 9,179,000 gallons) and the municipal swimming pool contribute the amount of water not billed. Water used to flush mains, fight fires, and main breaks, old meters and leakage accounts for the remainder of that not billed. *Industrial*

*Customers-Monthly Billing \$3.05 per Thousand Gallons; Residential Rates (Semi-Annual Billing) 0-15,000 gallons-\$50.00; over 15,000 gallons; \$3.05 for each 1,000 gallons thereafter; If the meter is broken or not working there will be a 40,000-gallon charge. Rates will be billed on a per unit basis (Multiple Dwellings). Industrial Rate is \$3.05 a thousand gallons.*

#### **ARE THERE CONTAMINANTS IN OUR DRINKING WATER?**

In accordance with State regulations, the Village of Fort Edward routinely monitors your drinking water for numerous contaminants. We test your drinking water for inorganic contaminants, radiological contaminants, lead and copper, nitrate, volatile organic contaminants, and synthetic organic contaminants. In addition, we test 4 samples for coliform bacteria each month and the Fort Edward WD #2 does 1 coliform sample each month. The tables presented on pages 4 and 6 depict which contaminants were detected in your drinking water. The state allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old and is noted. For a listing of the parameters we analyzed that were not detected along with the frequency of testing for compliance with the NYS Sanitary Code, see Appendix A.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the New York State Department of Health, Glens Falls District Office at (518) 793-3893.

#### **WHAT DOES THIS INFORMATION MEAN?**

As you can see from the attached tables on pages 3 and 4, our water systems had no violations. We would like to note that our water is tested annually for sodium. Although there is no MCL for sodium there are several dietary warnings which are on page 4, footnote #4. Although nitrate was detected below the MCL for the Village of Fort Edward, it was detected at times at concentrations greater than 5 ppm which is greater than one-half of the MCL. Therefore, we are required to present the following information on nitrate in drinking water:

*Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.*

New York State has adopted the first in the nation drinking water standard for 1,4-Dioxane along with one of the lowest maximum contaminant levels for PFOA and PFOS. Public Water Supplies in NYS are required to test for PFOA, PFOS and 1,4-Dioxane. PFOA and PFOS have Maximum Contaminant Levels (MCL) of 10 parts per trillion each while 1,4-Dioxane has an MCL of 1.0 parts per billion. The Village of Fort Edward has completed its 1<sup>st</sup> quarter monitoring showed compliance with the new MCLs for PFOA,PFOS & no detects for 1,4-Dioxane. The data is presented in the table.

We have learned through our monitoring and testing that some constituents have been detected; however, these compounds were detected below New York State requirements. MCL's are set at very stringent levels..

#### **IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

During 2022, our system was in compliance with applicable State drinking water operating, and reporting requirements.

#### **DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbiological pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

#### **INFORMATION ON LEAD**

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Fort Edward is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes

by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Fort Edward at (518) 792-0419 Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

**WHAT IS THE SOURCE WATER ASSESSMENT PROGRAM (SWAP)?**

To emphasize the protection of surface and ground water sources used for public drinking water, Congress amended the Safe Drinking Water Act (SDWA) in 1996. The amendments require that New York State Department of Health's Bureau of Public Water Supply Protection is responsible for ensuring that source water assessments are completed for all of New York's public water systems.

A source water assessment provides information on the potential contaminant threats to public drinking water sources:

- ◆ Each source water assessment will: determine where water used for public drinking water comes from (delineate the source areas).
- ◆ Inventory potential sources of contamination that may impact public drinking water sources.
- ◆ Assess the likelihood of a source water area becoming potential contaminated.

A SWAP summary for our water supply is attached to this report.

**WATER CONSERVATION TIPS**

The Village of Fort Edward encourages water conservation. There are a lot of things you can do to conserve water in your own home. Conservation tips include:

- ◆ Only run the dishwasher and clothes washer when there is a full load
- ◆ Use water saving showerheads
- ◆ Install faucet aerators in the kitchen and the bathroom to reduce the flow from 4 to 2.5 gallons per minute
- ◆ Water gardens and lawn for only a couple of hours after sunset
- ◆ Check faucets, pipes and toilets for leaks and repair all leaks promptly

**CAPITAL IMPROVEMENTS**

There were no major capital improvements done in 2022.

**CLOSING**

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit our customers. We ask that all our customers help us protect our water sources. Please call our office if you have questions.

TOWN OF FORT EDWARD WD #2 TABLE OF DETECTED CONTAMINANTS							
Public Water Supply Identification Number NY5730110							
Contaminant	Violation Y/N	Date of Collection	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>							
Copper Range of copper concentration	N	8/27/20	0.121 <sup>1</sup> 0.0144- 0.155	mg/l	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead Range of lead concentration	N	8/27/20	2.75 <sup>2</sup> ND-3	µg/l	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection Byproducts</b>							
Haloacetic Acids (HAA5)	N	8/1/22	23.0	µg/l	N/A	MCL=60	By-product of drinking water chlorination
TTHM[Total Trihalomethanes]	N	8/1/22	11.3	µg/l	N/A	80	By-product of drinking water chlorination
Chlorine (average) [ daily samples] Range	N	daily testing	0.56 0.20-0.87	mg/l	MRDLG N/A	MRDL MCL=4	Used in the treatment and disinfection of drinking water
<b>FOOTNOTES-</b>							
1. The level presented represents the 90 <sup>th</sup> percentile of 6 test sites. The action level for copper was not exceeded at any of the 6 sites tested							
2. The level presented represents the 90 <sup>th</sup> percentile of 6 test sites. The action level for lead was not exceeded at any of the 6 sites tested							

**VILLAGE OF FORT EDWARD TABLE OF DETECTED CONTAMINANTS**  
**Public Water Supply Identification Number NY5700119**

Contaminant	Violation Y/N	Date of Collection	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Microbiological Contaminants</b>							
Turbidity <sup>1</sup> (Highest turbidity sample)	N	5/24/22	0.08	NTU	N/A	TT=1.0 NTU	Soil runoff
Monthly Average of Samples Meeting Performance Standard	N		100%	NTU		TT= 95% samples < 0.3	
<b>Inorganic Contaminants</b>							
Barium	N	2/7/22	7.9	µg/l	5000	MCL=5000	Erosion of natural deposits
Chloride	N	2/7/22	74.5	mg/l	N/A	250	Naturally occurring or indicative of road salt contamination.
Copper Range of copper concentration	N	7/28/21-8/2/21	0.18 <sup>2</sup> 0.025-0.220	mg/l	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits;
Lead Range of lead concentration	N	7/28/21-8/2/21	2.6 <sup>3</sup> ND-11.6	µg/l	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nickel	N	2/7/22	0.6	µg/l	N/A	N/A	Discharge from steel industry
Nitrate (as Nitrogen) quarterly samples Average Range of nitrate concentrations	N	2/7/22 5/2/22 7/11/22 11/22/22	6.08 5.68-7.03	mg/l	10	MCL=10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Odor	Y	2/7/22	4	units	N/A	MCL=3	Natural sources
pH	N	2/7/22	7.01	units		6.5-8.5	Geology; Naturally occurring
Sodium <sup>4</sup>	N	2/7/22	46.2	mg/l	N/A	N/A	Naturally occurring; Road salt; Water softeners; Animal waste
Sulfate	N	2/7/22	10.1	mg/l	N/A	250	Naturally occurring
<b>Synthetic Organic Chemicals</b>							
6.2 FTS	N	3/7/22	5.8	ng/l	N/A	MCL=10 <sup>5,7,8</sup>	Released into the environment from widespread use in commercial and industrial applications
PFBS			2.1				
PFBA			2.2				
PFHpA			0.98				
PFHxS			0.78				
PFHxA			1.8				
PFOS			1.3				
PFOA			2.7				
PFPeA			2.3				
<b>Stage 2 Disinfection Byproducts (Quarterly samples)</b>							
Haloacetic Acids (HAA5) <sup>6</sup> Range of Values for HAA5	N	2/7/22 5/2/22	29.8 6.9-35.4	µg/l	N/A	MCL=60	By-product of drinking water disinfection
TTHM [Total Trihalomethanes] (Average) <sup>6</sup> Range of values for Total Trihalomethanes	N	8/1/22 11/7/22	43.3 13.3-48.2	µg/l	N/A	MCL=80	By-product of drinking water chlorination
Chlorine (average) [ daily samples] Range	N	daily testing	1.38 0.927-1.689	mg/l	MRDLG N/A	MRDL MCL=4	Used in the treatment and disinfection of drinking water
<b>Total Organic Carbon (quarterly samples)</b>							
Raw Water (range of values) Treated Water (range of values)	N	2/7/22 5/2/22 8/1/22 11/7/22	1.68-3.02 1.1 -1.76	mg/l	NA	TT	Organic material both natural and man made; Organic pollutants, decaying vegetation.

**FOOTNOTES-**

1. Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. Level detected represents the highest level detected. State regulations require that entry point turbidity must always be below 1.0 NTU. The regulations also require that 95% of the turbidity samples collected have measurements below 0.3 NTU. Distribution system turbidity performed 5 times a week with 0.18 NTU being the average level detected. The level presented represents the 90<sup>th</sup> percentile of the 20 test sites. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90<sup>th</sup> percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 20 samples were collected at your water system and the 90<sup>th</sup> percentile value was the sample with the third highest value (level detected 0.18 mg/l). The action level for copper was not exceeded at any of the sites tested.
2. The level presented represents the 90<sup>th</sup> percentile of 20 test sites. The action level for lead was not exceeded at any of the 20 sites tested in 2021.
3. The level presented represents the 90<sup>th</sup> percentile of 20 test sites. The action level for lead was not exceeded at any of the 20 sites tested.
4. Water containing more than 20 mg/l should not be consumed by persons on severely restricted sodium diet.
5. The MCL of 10 ng/l is for PFOA and PFOS. The other compounds listed in the table are not currently regulated and have no associated MCL.
6. The average is based on a Locational Running Annual average. The average shown represents the highest LRAA for the 4 quarters. The highest HAA5 and THM LRAAs was in the 2<sup>nd</sup> quarter of 2022.
7. All perfluoroalkyl substances, besides PFOA and PFOS, are considered Unspecified Organic Contaminants (UOC) which have an MCL=0.05 mg/L or 50,000 ng/l.
8. USEPA Health Advisory Levels identify the concentration of a contaminant in drinking water at which adverse health effects and/or aesthetic effects are not anticipated to occur over specific exposure durations. Health Advisory Levels are not to be considered Legally enforceable federal standards and are subject to change as new information become available PFBS (2000 ng/l) and HFPO-DA (10 ng/l) also have Health Advisory Levels.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter (µg/l)* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Parts per trillion (ppt) or Nanograms per liter (ng/l)*-one part per trillion corresponds to one part of liquid to one trillion parts of liquid.

*Non-Detects (ND)* - laboratory analysis indicates that the constituent is not present.

*Nephelometric Turbidity Unit (NTU)* - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

*90<sup>th</sup> Percentile Value*- The values reported for lead and copper represent the 90<sup>th</sup> percentile. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90<sup>th</sup> percentile is equal to or greater than 90% of the lead and copper values detected at your water system.

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Treatment Technique (TT)* -A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

*Maximum Contaminant Level* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal* - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)*: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)*: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

*Locational Running Annual Average (LRA)*: The LRA is calculated by taking the average of the four most recent samples collected at each individual site.

*N/A-not applicable*

**Fort Edward Village  
PWSID# NY5700119  
AWQR SWAP Summary**

The NYS DOH has evaluated this Public Water System's (PWS) susceptibility to contamination under the Source Water Assessment Program (SWAP), and their findings are summarized in the paragraph below. It is important to stress that these assessments were created using available information and only estimate the potential for source water contamination. Elevated susceptibility ratings do not mean that source water contamination has or will occur for this PWS. This PWS provides treatment and regular monitoring to ensure the water delivered to consumers meets all applicable standards.

The assessment area for this drinking water source contains no discrete potential contaminant sources, and none of the land cover contaminant prevalence ratings are greater than low. However, the high mobility of microbial contaminants in reservoirs results in this drinking water intake having medium-high susceptibility ratings for protozoa and enteric bacteria and viruses. Furthermore, reservoirs are highly susceptible to water quality problems caused by phosphorus additions.

